

CITY OF ST. CHARLES ELECTRIC SERVICES
ON LINE LOAD TAP CHANGER INSPECTION AND MAINTENANCE
TECHNICAL SPECIFICATION
ADDENDUM 1

The following is a list of clarifications to the LTC maintenance specification:

- 1.0 The wording in section 5.01 is changed as:
 - 5.01 Work hours are scheduled from 7:00 a.m. to 5:00 p.m. five days a week from Monday through Friday. Work on Saturday is possible if it is required to finish all work and allows the maintenance crew to leave without having to spend the weekend.
- 2.0 The wording in section 6.02 is changed to:
 - 6.02 The City shall be responsible for switching, lock out, and grounding of any equipment necessary to establish a safe work area. City crews will make every effort to stay ahead of the LTC maintenance crew and have transformers switched out and grounded.
- 3.0 Section 2.24 added:
 - 2.24 If replacement oil is required for the LTC's, the contractor is to provide the oil. If the oil needs to get to the City before the contractor crews arrive, the oil is to be delivered to the substations. If required, city crews can help in the offloading with a line truck.